CIVIL TECH LABS

5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph: 080 - 4114 2867, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AEE, Shettyhalli Sub Division BBMP.
Name of the project	Consultancy services for Construction Supervision, Project management and Quality control for the 2 works in **Dasarahalli Division Package-01**
Name of Work	Improvements and Asphalting to Babanna Layout new vegetable market surrounding area roads in Ward No 12, Shettyhalli Sub divison
Name of Agency	M/s. K. R. I. D. L.
Grade of Concrete	M-15
No. of cubes tested	3
Dimension of Specimen	150mmx150mmx150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS: 516-1959 (Reaffirmed 2013)

Sl. No.	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	CC-Work (Precast Slab 100mm Thick)	12/03/2019	19/03/2019	7	8.23	256	**11.38**	**11.47**
2					8.25	258	**11.47**	
3					8.27	260	**11.56**	

Note:
1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any correction invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

CIVIL TECH LABS BANGALORE

(KHUSHBOO L.)
Quality Manager

AE-13

ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿಬಿಎಂಪಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಪೈಪತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಂ. ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

AE ward 12.